


REPLY TO BIDDER'S QUERIES-III

	Bid Document for the Procurement of 5000 SCMH, Twin Stream Canopied DRS with USM for Kanpur, Bareilly and Jhansi		Bid Document No.: CUGL/C&P/TEN2324/39 dated 12.07.2023 (E-Tender No. 55336)
Sr. No.	Tender Clause No. / Annexures	Bidder's Queries/ Observation/Comments	CUGL Response
1	Technical Specification	Gas Velocity permitted in Piping. Kindly clarify.	Gas velocities in piping up to 20 m/sec before filter and 40 m/sec (120 ft/sec) after filter, at peak flow conditions.

Bidder are required to submit the "REPLY TO BIDDER'S QUERIES" alongwith the bid duly signed & stamped.

(Handwritten Signature)

(Handwritten Date: 23/08/2023)