



CORRIGENDUM No. 1

**SUPPLY,INSTALLATION,TESTING,COMMISSIONING AND COMPREHENSIVE MAINTENANCE FOR MOTOR
DRIVEN 400 SCMh VARIABLE INLET PRESSURE (VIP) CNG INTEGRATED COMPRESSOR PACKAGE
(E-Tender ID - 50606)**

Date: 28.06.2021

Tender Document No. P.014714 G 11031 R007

Project: CGD Expansion Project

Owner: Central UP Gas Ltd

Sr. No.	Description	Tender Page No.	Clause/ Para/ Section	Amendment/Addition/Modification/Deletion	
Volume I of II					
1	Details of Bid Documents	7 of 109	8.2 of IFB/Tender Document Number Date of Issue	Modification	Please read the clause as, P.014714 G11031 R007 08.06.2021
2	Details of Bid Documents	7 of 109	8.4 of IFB/Pre bid meeting through VC	Modification	Please read the clause as, 16.06.2021 at 1500 HRS IST
3	Details of Bid Documents	7 of 109	8.5 of IFB/Bid submission due date and time on e-tendering portal (https://cugl.abcpocure.com)	Modification	Please read the clause as, Bid submission date and time - 29.06.2021 upto 1500 Hrs IST
4	Details of Bid Documents	7 of 109	8.6 of IFB/Unpriced bid opening date and time on e-tendering portal (https://cugl.abcpocure.com)	Modification	Please read the clause as, Un-Priced bid opening due date and time - 29.06.2021 upto 1530 Hrs IST
Volume II of II					
5	UTILITIES	23 of 153	9.0 of Volume II of II	Modification	Please read the clause as, Bidder shall make his own provision for Instrument air if required with an electric motor driven air compressor with a suitably sized receiver & Refrigerant type air drier system. Air Compressor motor should be 415 V squirrel cage motor DOL / star delta starter having overload protection, single phase preventer.

Surshi



CORRIGENDUM No. 1

**SUPPLY,INSTALLATION,TESTING,COMMISSIONING AND COMPREHENSIVE MAINTENANCE FOR MOTOR
DRIVEN 400 SCMH VARIABLE INLET PRESSURE (VIP) CNG INTEGRATED COMPRESSOR PACKAGE
(E-Tender ID - 50606)**

Date: 28.06.2021

Tender Document No. P.014714 G 11031 R007

Project: CGD Expansion Project

Owner: Central UP Gas Ltd

Sr. No.	Description	Tender Page No.	Clause/ Para/ Section	Amendment/Addition/Modification/Deletion	
6	SCOPE OF SUPPLY FOR EACH INTEGRATED CNG COMPRESSOR PACKAGE	7 of 153	6.0 of Volume II of II	Modification	Please read the clause as, Duplex suction filters with filtration level upto 5 Micron to be provided outside battery limits of the package at the inlet of package with DP gauge after Y- type strainer.
7	ANNEXURE – I : GUARANTEED PARAMETERS	49 of 153	ANNEXURE – I : GUARANTEED PARAMETERS of Volume II of II	Addition	Following note is added in Annexure I : Loading of package will be done on variable suction pressure , however, bidder to also quote Guaranteed power consumption for online fixed suction pressure. Same shall be used for PAT and Penalties at site.

Note:

1. All other terms & conditions of tender document remain unaltered.
2. Bidders are requested to visit CUGL / Tractebel website regularly for further announcement .

Surshi

[Signature]