सेन्ट्रल यू.पी. गैस लिमिटेड (गेल (इंडिया) लिमिटेड एवं भारत पेट्रोलियम का संयुक्त उद्यम)



Central U.P. Gas Limited

(A Joint Venture of GAIL (India) Limited and BPCL)

CORRIGENDUM-2

Date: 05.08.2020

Ref.:

Bid Document No. CUGL/C&P/TEN2021/20,219,008 dated 10.07.2020 for the

Procurement of Commercial & Industrial Regulators for Kanpur, Unnao, Bareilly &

Jhansi.

Sub.: Corrigendum-2

Please note the following corrigendum-2

Sr. No.	Clause No.		Amended Clause
1	Technical Data Sheets of regulator of 800 mbar & 4- 1 Bar, Page no. 101 & 106 of technical part of tender	regulator with in-built two stage pressure reducing valve type balance regulating unit to ensure a constant outlet pressure and with pressure slam shut device for	pressure and with pressure slam shut device
2	Technical data sheets of all regulators	Casting and body of steel confirming to ASTM 216 WCB and water - weather proof IP 65/corrosion resistant for outdoor installation	Cast aluminium alloy or WCB or Spheroidal graphite cast iron as per Standard EN 334 confirming water -weather proof IP 65/corrosion resistant for outdoor installation
3	6.0 Delivery Schedule of Commercial part, page no. 91	Quantity against individual lots shall be intimated within the delivery order and delivery shall be completed within 6 weeks from issue of respective delivery order.	Quantity against individual lots shall be intimated within the delivery order and delivery shall be completed within 8 weeks from issue of respective delivery order.
4	Technical datasheet of 4- 1 Bar regulator , page no. 106	Inlet Pressure range 1-4 bar.	Inlet Pressure range 2-4 bar.

Note: All other terms & conditions of tender shall remain same.

This corrigendum-2 is to be treated as part of the original bid document and while submitting your offer, corrigendum-2 shall also be signed and stamped along with bid document.

Thanking you

For, Central U.P. Gas Limited

Managar (C.S.D)

Sr. Manager (C&P)

रजिस्टर्ड आफिस : सातवाँ तल, यूपीएसआईडीसी कॉम्पलैक्स, ए-1/4, लखनपुर, कानपुर - 208 024 उ.प्र.• दूरभाष : 0512-2585001, 2583462 • फैक्स : 2582453 • वेबसाइट : www.cugl.co.in